CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0587:107 Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: American Security Equipment Co., Division of Kobishi America Inc., 228 E. Star of India

Lane, Carson CA 90746 Contact: Toby Tabata (310) 538-4670

DESIGN: Model HP-24, HP-24T horn; Models HP-24SL, SHP24-1575, SHP24T-1575, SHP24-110,

SHP24T-110, SHP24-153075, SHP24T-153075, *SHP24-75110 and *SHP24T-75110 horn/strobes. Refer to listee's data sheet for additional detailed product description and

operational considerations.

RATING: 10-28 VDC

All strobes rated at 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and audibility ratings and UL label.

APPROVAL: Listed as horns or horn/strobes for use with separately listed compatible fire alarm

control units. *For indoor use only.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the appliances must be used with a fire alarm control unit that can generate the temporal pattern signal.

Refer to listee's Installation Instructions Manual for details.

NOTE: Model HP-24SL is not suitable for fire alarm visual evacuation signal or for the hearing

impaired.

*Rev. 05-08-2002 BH

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the

test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MAY 16, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager